

District Level Water Analysis Laboratory UP Jal Nigam (Rural) -Mau



Office Executive Engineer Construction Division UP Jal Nigam (Rural), Mau- 275101

Report No . TC/MANIA (25 (45)	, ,	
Report No.: TC/MAU/25/123	Date: 24.06.2025	No. of F
達模が発えています。	Customer Details	

010	Customer Betains
Office Name and Address	St Xavier's Sehart Malari Mahammadahad Gohana Dist Mau

		on, manny men				
		Basic D	etails of San	iple		
District		Block		Mohammadabad Gohana		
Habitation		Mau			School	
Water Source		School campus			MAU/25/06/054	
Quantity of Sample		B.W				
Sample Received Date		1000 ml (Normal)		te	21.06.2025	
	21.06.202	21.06.2025		у	By Client	
Sampling Method Used	Client sco	Client scope		sitor	By Client	
Analysis Start Date	21.06.2025		Analysis Completion date		23.06.2025	
Temperature(°C)	27°C	27°C			52%	
S. No. Analysed Parameters	Unit	Observed Value	Specification as per IS 10500:2012 (Second Revision) Acceptable Permissible		Ref. Methods of Analysis	
11.1	2	1	Limit	Limit	7	

The state of	S. No.	Analysed Parameters	Unit	Observed Value	10500:2012 (Second Revision)		Ref. Methods of Analysis
5					Acceptable Limit	Permissible Limit	,
	11.1	, 2	3	4	5	6	7
	1.	Colour	(Hazen)	<5	5	15	APHA 24rd Edition-2120
	2.	рН	-	7.16	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022
	3.	Turbidity	NTU	0.55	1	5	IS 3025 (Part 10):2023
	4.	Total Dissolved Solids	mg/l	312	500	2000	IS 3025 (Part 16): 2024
	5.	Total Hardness (as CaCO3)	mg/l	184	200	600	IS 3025 (Part 21): 2023
	6.	Calcium (as Ca)	mg/l	28.0	75	200	IS 3025 (Part 40): 2019
	7.	Magnesium (as Mg)	mg/l	37.9	30	100	IS 3025 (Part 46): 2024
	8.	Chloride (as CI)	mg/l	30.9	250	1000	IS 3025 (Part 32): 2019
	9.	Total Alkalinity (as CaCO3)	mg/l	190	200	600	IS 3025 (Part 23): 2023
	10.	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
- 1	11.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3035 (D-115) 2010

Note

- 1. This certificate refers only to the particular sample(s) submitted for analysis.
- 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
- 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- 4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
- 5. Parameters above Permissible Limit are written in **bold**. (BDL=Below detection limit)
- 6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
- 7. Sample is not Collected by Lab.
- 8. Star (*) Indicate parameters are not under NABL accreditation.

(Report prepared by)

(Raber Amarysis (Raber Amarysi (Raber Amarysis (Raber Amarysis (Raber Amarysis (Raber Amarysis

Laboratory Contact detail: email: labmaunath@gamil.com, Mob. 6307933383